

2021 6 15
2021 6 15

	1	2	3	4	5	6	7	8	9	10	11	12
						PH						
		NTU				PH	mg/L	CFU/mL	CFU/mL	mg/L	mg/L	CFU/mL
	15	8.52	0		28	6.82	2.00	-	-	0.03	-	-
	<5	0.22	0		28	6.83	0.88	-	-	-	0.24	-
-	<5	0.19	0		28	6.72	0.72	-	-	-	0.03	-
-9	<5	0.21	0		28	6.95	0.72	-	-	-	0.08	-
-	<5	0.22	0		28	6.76	0.80	-	-	-	0.05	-
-	<5	0.02	0		28	6.97	0.88	-	-	-	0.10	-
GB3838-2002			3		35	6.9	6		10000	1.0		10000
GB5749-2006	15	1				6.5 8.5	3	100		0.5	0.1	
	GB/ T5750-2006											