

2023 07 24

2023 07 24

				2023 7 24												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
				NTU			pH		mg/L	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L
2307241()	-	-	30	24.4	0		7.27	3.20	-	0.190	/	/	/	-	0.037	0.030
2307242()	0.17	0.26	5	0.210	0		7.35	1.28	0.02	-	/	/	-	/	0.02	0.01
GB3838-2002							6.9	6		1.0			10000		0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1			6.5 8.5	3	0.5		100				0.3	0.1
	(GB5750-2006)					1 2										