

2023 08 09

2023 08 09

				2023 8 09												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
				NTU			pH		mg/L	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L
2308091()	-	-	25	21.0			7.12	2.88	-	0.172	/	/	/	-	0.02	0.053
2308092()	0.22	0.39	5	0.126			7.04	1.28	0.02	-	/	/	-	/	0.02	0.011
GB3838-2002							6.9	6		1.0			10000		0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1			6.5 8.5	3	0.5		100				0.3	0.1
	(GB5750-2006)					1										
						2										